

Trinkwasserbefund Reichenthal

Herbst 2023

	Einheit	Ergebnis	Indikator- Werte	PW	Best-Gr
Physikalische Parameter					
Wassertemperatur	Grad C	13,6			
pH-Wert		7,9	6,5 – 9,5		
Chemische Parameter					
Gesamthärte	dH	4,90			0,1
Carbonathärte	dH	4,90			0,2
Calcium (Ca)	mg/l	27,0			1
Magnesium (Mg)	mg/l	4,88			1
Nitrat (NO ₃)	mg/l	3,5		max. 50	1
Nitrit (NO ₂)	mg/l	<0,01		max. 50	0,01
Chlorid (Cl)	mg/l	4,8	max. 200		1
Sulfat (SO ₄)	mg/l	10,8	max. 750		1
Natrium (Na)	mg/l	12,4	max. 200		0,5
Kalium (K)	mg/lg	1,37			0,5